
129826







- IP ingress protection IP65 rating
- Wet Area LED Downlight



۲

superlux Model: LDL-IP65-SI





instructions: Installation

Important:

install using a registered electrician. Isolate the electrical power supply

- 1. Minimum cavity depth required 120mmH
- SCB=20mm, HCB=50mm When choosing downlight position ensure that
- 3. Cavity size must not be less than 0.2m°
- 4. Cut hole in ceiling
- 5. Connect power supply to LED driver Brown-(L) and Blue- (N)
- and slide into the ceiling e. Insert downlight into the ceiling, holding back the spring steel clips
- members and building elements. distances are compromised. Required clearance from structural Classification IC-4 WARNING - Risk of overheating or Fire if clearance
- where ambient temperatures exceed 30 degrees Please note that this downlight should not be installed
- V Can be mounted into timber ceilings
- IP65 below ceiling only.

